

State of North Carolina
Department of Environment,
Health and Natural Resources
Regional Health Office

James B. Hunt, Jr., Governor
Jonathan B. Howes, Secretary
Leesha L. Fuller, Regional Manager



January 19, 1995

Bob Rowe
Parrish Tire Company
8800 North Point Blvd.
Winston-Salem, NC 27106

SUBJECT: Underground Storage Tank (UST) Closure Assessment at Parrish Tire Company - North Point, 8800 North Point Blvd., Winston-Salem, Forsyth County

Dear Mr. Rowe:

A copy of the city map with site location was received by this office on January 13, 1995. In order to determine whether or not the closure was performed in accordance with State and Federal regulations, the Groundwater Section must be provided with the information we have requested twice within *30 days from receipt of this letter*.

- * a description of the decontamination procedures used during sample collection (I think that you need to ask the person who took the samples how did he or she decontaminate or clean the sampling tool, stainless steel, before and between sample collections).

Your cooperation is appreciated. Please refer to the file name, **Parrish Tire Company - North Point**, on the cover letter of your reply. This will help us speed up the review. If you have any questions please contact me at the letterhead address and/or telephone number.

Sincerely

Shuying Wang
Hydrogeological Technician I

cc: WSRO Files

State of North Carolina
Department of Environment,
Health and Natural Resources
Regional Health Office

James B. Hunt, Jr., Governor
Jonathan B. Howes, Secretary
Leesha L. Fuller, Regional Manager



January 19, 1995

Bob Rowe
Parrish Tire Company
8800 North Point Blvd.
Winston-Salem, NC 27106

SUBJECT: Underground Storage Tank (UST) Closure Assessment at Parrish Tire
Company - North Point, 8800 North Point Blvd., Winston-Salem, Forsyth
County

Dear Mr. Rowe:

A copy of the city map with site location was received by this office on January 13, 1995. In order to determine whether or not the closure was performed in accordance with State and Federal regulations, the Groundwater Section must be provided with the information we have requested twice within *30 days from receipt of this letter*.

- * a description of the decontamination procedures used during sample collection (I think that you need to ask the person who took the samples how did he or she decontaminate or clean the sampling tool, stainless steel, before and between sample collections).

Your cooperation is appreciated. Please refer to the file name, **Parrish Tire Company - North Point**, on the cover letter of your reply. This will help us speed up the review. If you have any questions please contact me at the letterhead address and/or telephone number.

Sincerely

A handwritten signature in cursive script, appearing to read 'Shuying Wang', is written over a horizontal line.

Shuying Wang
Hydrogeological Technician I

cc: WSRO Files